




Building Bricks India Pvt Ltd

Made from The Earth For A Lifetime

QUALITY REPORT FOR BRICKS		
NAME OF ORGANIZATION: BUILDING BRICKS (INDIA) PVT LTD	No.	
	SITE :DOLAVLI	
	DATE:21/08/2023	
QUALITY REPORT		
MATERIAL: Bricks	QUALITY: 2nd CLASS	SUPPLIED BY: BBI
CHALLAN NO.	DATE: 21/08/2023	TRADE MARK: BBI
TEST TAKEN BY : BBI LAB		
HOLLOW BRICKS 6"		
SR NO	TEST TAKEN	RESULT OBTAINED
1	Color	Reddish and uniform
2	Edges	Not broken and sharp (small air crack)
3	Weight (KG)	4.5 to 4.7
4	Size (mm)	230 x 150 x 90
5	Water Absorption	15.00%
6	Soundness Test	Matelic sound
7	Burnt	As per noms well burnt
8	Strength (Compressive)(KN)	450
9	Density (kg/M ³)	1474
		

1st Floor, Sub-Plot "I", Behind Dheeraj Heritage Residency II, Near Daulat Nagar Circle,
Linking Road Ext., S.V. Road, Santacruz West, Mumbai 400054.

Tel: 022-30100786 • Email: bbi@buildingbricksindia.com • Website: www.buildingbricksindia.com