

	QUALI	TY REPORT FOR BRICK	<u>S</u>	
NAME OF ORGANIZATION:		No.	No.	
BUILDING BRICKS (INDIA) PVT LTD		SITE : Plan	t test samples	
		DATE:		
		QUALITY REPORT		
MATERIAL: Bricks QUA		QUALITY: 1ST CLASS	SUPPLIED BY: BBI	
I/! = 11/2 141 = 1.101.10		DATE: 21/08/2023	TRADE MARK: BB	
	N BY : BBI LAB			
	HOLLOW	BRICKS 4"(SIX SQU	JARE)	
		Dittietto i tentesta		
SR NO	TEST TAKEN	Division - June 4	RESULT OBTAINED	
SR NO				
1	TEST TAKEN	Reddish a	RESULT OBTAINED	
I SON TO THE SECOND	TEST TAKEN Color Edges	Reddish a	RESULT OBTAINED	
1 2	TEST TAKEN Color	Reddish a Not broke	RESULT OBTAINED and uniform an and sharp	
1 2 3	TEST TAKEN Color Edges Weight (KG)	Reddish a Not broke 2.40	RESULT OBTAINED and uniform an and sharp	
1 2 3 4	Color Edges Weight (KG) Size (mm)	Reddish a Not broke 2.40 225 x 100 14.50% Metallic s	RESULT OBTAINED and uniform an and sharp 2 x 75 sound	
1 2 3 4 5	TEST TAKEN Color Edges Weight (KG) Size (mm) Water Absorption	Reddish a Not broke 2.40 225 x 100 14.50% Metallic s	nd uniform en and sharp	
1 2 3 4 5	TEST TAKEN Color Edges Weight (KG) Size (mm) Water Absorption Soundness Test	Reddish a Not broke 2.40 225 x 100 14.50% Metallic s	RESULT OBTAINED and uniform an and sharp 2 x 75 sound	