

	QUALIT	Y REPOR	T FOR BRICKS						
NAME OF ORGANIZATION: BUILDING BRICKS (INDIA) PVT LTD			No. SITE :DOLAVLI DATE: 06/07/2023						
						Q	UALITY F	REPORT	1
					MATERIAL: Block		QUALI	TY: 1 ST CLASS	SUPPLIED BY : BB
CHALLAN NO.		DATE	: 06/07/2023	TRADE MARK: BB					
TEST TAK	(EN BY : BBI LAB		781						
	<u>H</u> (OLLOW	BLOCK						
SR NO	TEST TAKEN		RESULT OBTAINED						
1	Color		Reddish and uniform						
2	Edges		Not broken and sharp						
3	Weight (KG)		7						
4	Size (mm)		500X100X200						
5	Water Absorption		15.00%						
	Soundness Test		Matelic sound						
6		Burnt		As per noms well burnt					
7	Burnt		As per noms we	II burnt					
	Burnt Strength (Compressive)(KN/N	/IM ²)	As per noms we	II burnt					