

QUALITY REPORT FOR BRICKS NAME OF ORGANIZATION: **BUILDING BRICKS (INDIA) PVT LTD** SITE :DOLAVLI DATE: 06/07/2023 **QUALITY REPORT** QUALITY: 1ST CLASS SUPPLIED BY : BBI MATERIAL: Block : 06/07/2023 TRADE MARK: BBI CHALLAN NO. **TEST TAKEN BY: BBI LAB** HOLLOW BLOCK **RESULT OBTAINED** SR NO **TEST TAKEN** Color Reddish and uniform Not broken and sharp **Edges** 3 Weight (KG) 10.8 400X200X200 Size (mm) 4 Water Absorption 15.00% 5 Matelic sound Soundness Test 6 As per noms well burnt 7 Burnt 3.5 Strength (Compressive)(KN/MM2) 8 Density (kg/M3)