




Building Bricks India Pvt Ltd

Made from The Earth For A Lifetime

| QUALITY REPORT FOR BRICKS | | |
|--|--------------------------------|-------------------------|
| NAME OF ORGANIZATION: BUILDING BRICKS (INDIA) PVT LTD | No. | |
| | SITE : Plant test samples | |
| | DATE: | |
| QUALITY REPORT | | |
| MATERIAL: Bricks | QUALITY: 1 ST CLASS | SUPPLIED BY: BBI |
| CHALLAN NO. NA | DATE: 21/08/2023 | TRADE MARK: BBI |
| TEST TAKEN BY : BBI LAB | | |
| HOLLOW BRICKS 4" | | |
| SR NO | TEST TAKEN | RESULT OBTAINED |
| 1 | Color | Reddish and uniform |
| 2 | Edges | Not broken and sharp |
| 3 | Weight (KG) | 2.60 |
| 4 | Size (mm) | 230 x 100 x 75 |
| 5 | Water Absorption | 14.50% |
| 6 | Soundness Test | Metallic sound |
| 7 | Burnt | As per norms well burnt |
| 8 | Strength (Compressive)(KN) | 480 |
| 9 | Density (kg/M ³) | 1579 |
| Signature  | | |